






**2013
CA MECHANICAL CODE
904.2 & 305.0**

**TABLE
904.2**



	A	B	C	D	E _L	E _R	F	INPUT
MODEL FGZ-2	1'	6"	6"	0"	0"	0"	C	80,000

A. CLEARANCE ABOVE BONNET
C. CLEARANCE FROM FLUE OR VENT CONNECTOR IN ANY DIRECTION
F. TYPE OF FLOOR ("C"= COMBUSTIBLE, "NC"= NONCOMBUSTIBLE)



NOTE: WORKING SPACE
REQUIREMENTS SHALL BE
MAINTAINED AS REQUIRED
IN OTHER SECTIONS OF
THE CODE.

REQUIRED MINIMUM CLEARANCE
ON ALL SIDES AND FRONT PER
MANUFACTURER'S INSTALLATION
INSTRUCTIONS.

ENCLOSURE DOOR WIDE
ENOUGH TO PERMIT REMOVAL
OR REPLACEMENT AND SERVICING,
BUT MINIMUM 24" (610 mm) WIDE
FOR HEATING EQUIPMENT.
(REFER TO SECTION 314.)

